Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 391023036.0
CLIENT # WAT15
DATE SUBMITTED: 10/23/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: DRINKING WATER, GRAB SAMPLE
SAMPLE ID:
SAMPLE LOCATION: 1ST FLOOR FOUNTAIN LOWER-PATERSON CITY WATER., ST PHILIPS PATERSON

DATE SAMPLED: 10/23/2019 TIME SAMPLED: 07:30

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	10/27/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

405970

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

47 State Street Location

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 391023037.0
CLIENT # WAT15
DATE SUBMITTED: 10/23/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: WATER, GRAB SAMPLE
SAMPLE ID:
SAMPLE LOCATION: 1ST FLOOR FOUNTAIN UPPER-PATERSON CITY WATER., ST PHILIPS PATERSON

DATE SAMPLED: 10/23/2019 TIME SAMPLED: 07:32

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	10/27/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

405970

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

47 State Street Location

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 391023038.0
CLIENT # WAT15
DATE SUBMITTED: 10/23/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: WATER, GRAB SAMPLE
SAMPLE ID:
SAMPLE LOCATION: 2ND FLOOR FOUNTAIN-PATERSON CITY WATER., ST PHILIPS PATERSON

DATE SAMPLED: 10/23/2019 TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.001	mg/l	0.015	10/27/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

405970

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

47 State Street Location

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 391023039.0
CLIENT # WAT15
DATE SUBMITTED: 10/23/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: WATER, GRAB SAMPLE
SAMPLE ID:
SAMPLE LOCATION: KITCHEN SINK-PATERSON CITY WATER., ST PHILIPS PATERSON

DATE SAMPLED: 10/23/2019 TIME SAMPLED: 07:45

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	10/27/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

405970

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

47 State Street Location

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 390628005.0
CLIENT # WAT15
DATE SUBMITTED: 6/28/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE
SAMPLE ID:
SAMPLE LOCATION: ST., PHILIPS - BEACH ST.

DATE SAMPLED: 6/27/2019 TIME SAMPLED: 08:05

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 390628001.0
CLIENT # WAT15
DATE SUBMITTED: 6/28/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE
SAMPLE ID:
SAMPLE LOCATION: ST., PHILIPS - 1ST FLOOR FOUNTAIN STATE ST., PATERSON

DATE SAMPLED: 6/27/2019 TIME SAMPLED: 07:40

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 390628002.0
CLIENT # WAT15
DATE SUBMITTED: 6/28/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE
SAMPLE ID:
SAMPLE LOCATION: ST., PHILIPS - 1ST FLOOR FOUNTAIN LOWER STATE ST.,PATERSON

DATE SAMPLED: 6/27/2019 TIME SAMPLED: 07:41

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

REPORT OF ANALYSIS

REPORT # 390628003.0
CLIENT # WAT15
DATE SUBMITTED: 6/28/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE
SAMPLE ID:
SAMPLE LOCATION: ST., PHILIPS - 2ND FLOOR FOUNTAIN STATE ST., PATERSON

DATE SAMPLED: 6/27/2019 TIME SAMPLED: 07:50

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	<0.001	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.

Garden State Laboratories, Inc.

Bacteriological and Chemical Testing

Toll Free 800-273-8901
Telephone 908-688-8900
Fax 908-688-8966
Email: info@gslabs.com
Internet: www.gslabs.com

Main Lab
410 Hillside Avenue
Hillside, New Jersey 07205
NJDEP Lab Cert. #20044

Jersey Shore Lab
54 Main Street
Waretown, New Jersey 08758
NJDEP Lab Cert. #15037

Mathew Klein, M.S., Founder (1916-1996)
Harvey Klein, M.S., Laboratory Director
Jordan B. Klein, B.A., Exec. Vice President
Sharon Ercoliani, B.A., Laboratory Manager

REPORT OF ANALYSIS

REPORT # 390628004.0
CLIENT # WAT15
DATE SUBMITTED: 6/28/2019

TO: Water Dynamics
9 Valley Forge Drive

Whippany NJ 07981
ATT: Greg Dwyer

SAMPLE TYPE: DOMESTIC WATER, GRAB SAMPLE
SAMPLE ID:
SAMPLE LOCATION: ST., PHILIPS - BEACH ST., 1ST FLOOR FOUNTAIN, PATERSON

DATE SAMPLED: 6/27/2019 TIME SAMPLED: 08:00

ANALYSIS	RESULT	UNITS	MCL	DATE ANALYZED
Lead, EPA 200.9	0.004	mg/l	0.015	7/5/19

< = less than, not detected. Method Detection Limits and Reporting Limits available at www.gslabs.com/certnjdep.html
MCL = Maximum Contaminant Level allowed by State and Federal regulations.

Harvey Klein

398959

The liability of Garden State Laboratories, Inc. for services rendered shall in no event exceed the amount of the invoice.
When sample is collected by Garden State Labs, it is taken in accordance with Field Sampling Plan GSL.FS.01.01.
Main Lab certified by NJDEP #20044-TNI, NY Dept. of Health #11550 and PADEP #68-03680.